

August 18, 1994

Randy Lyman Springfield Public Works 840 Boonville Springfield, MO 65802

Dear Mr. Lyman

Enclosed are the results from a waste water test for United Machinery and Supply, 2315 E Chestnut Expressway. It was taken directly from the outflow from their settling pit in the wash area, before it is mixed with rinse waters, restrooms, etc.

Would you please review it and recommend whether we need to take any further action. Could you please fax your response to me at 866-1350 on or before 8/22/94,

If you have any further questions please call me at 866-8686.

Sincerely,

Mike Downie Vice President RECEIVED
AUG 19 1994
SEWER
OPERATIONS



Technical Services Laboratories, Inc.

1612 North Lexington Avenue - Springfield, Missouri 65802 417-873-3195 FAX: 417-864-4337 BN: 8-873-3195

UPON FUTURE CORRESPONDENCE REFER TO REPORT NUMBER

Material WASTEWATER	Test Report No <u>E-0192-A</u>
Customer_UNITED MACHINERY SUPPLY, INC.	Address SPRINGFIELD, MO
Purchase Order NoFile NoT-284_Specific	ation
Date Sample SubmittedDate Sample Received	vedAUGUST 1, 1994
Analysis of a water sample submitted by Mr. Larry Herndon	of United Machinery Supply, Inc.
Project Name	achinery, Springfield 1994
TEST PARAMETERS RESULTS	DATE OF ANALYSIS
Total Metals: Arsenic, EPA Method 206.2	August 2, 1994 August 2, 1994 August 2, 1994 August 2, 1994 August 2, 1994 August 2, 1994
pH, EPA Method 150.17.8	August 2, 1994
Oil and Grease EPA Method 413.21040 mg/L	August 2, 1994
Total Petroleum Hydrocarbons Analysis by EPA Method 418.1985 mg/L	August 2, 1994
Animal and/or Vegetable Oil and Grease (Oil and Grease minus TPH)55 mg/L	August 2, 1994
Flash Point, Closed Cup EPA Method 1010>205° F.	August 2, 1994
Total Cyanide EPA Method 335.2<0.004 mg/L	August 2, 1994
cc: Mr. Larry Herndon United Machinery and Supply Co. 2315 E. Chestnut Expressway Springfield, MO 65801	RECEIVED AUG 19 1994 SEWER OPERATIONS
Analyzed by: W. A. Middleton, D. E. Helmbrecht	Reported By: M. W. Woods
Approved by: R. E. Doughty, Laboratory Director	Date:August 3, 1994

CITY of SPRINGFIELD



Mr. Mike Downie Brittney, Inc. 1665 E. St. Louis

Springfield, MO 65802

August 19, 1994

Re: United Machinery and Supply sample results.

Dear Mr. Davis:

After reviewing the sample results, submitted to this office in a letter dated August 18, 1994, of a sample taken at United Machinery and Supply, it appears that the water from the settling pit does meet local discharge limits for the Southwest Wastewater Treatment Plant and can be discharged to the sanitary sewer. As I understand it, this sample was taken before mixing with any other waste stream, thereby making it a worse case situation.

I am enclosing a copy of Chapter 30, "Wastewater Regulations", for your information. You should pay particular attention to Section 30-24(a) for the local discharge limits that effect United Machinery and Supply.

If you have any questions please feel free to call at 864-1924.

Yours Truly,

Gene Pabst

Water Pollution Control Inspector

Surveillance & Enforcement

cc: Mr. Robert R. Schaefer, P.E., Superintendent of Sanitary Services.

Mr: Randy Lyman, Sewer Surveillance and Billing Supervisor.

TIME : AUG 19 '94 13:47 TEL NUMBER: 4178641918 NAME : SEWER OPERATIONS

HEF	DATE	TIME	DURATION	PGS	TO	1.1

764 AUG. 19 13:45 01/05 02 417 833 6607

HIDE